

Ordinance No. 1492

Passed February 5, 2019

ORDINANCE NO. 1492

AN ORDINANCE AMENDING ORDINANCE NO. 1441

AN ORDINANCE ESTABLISHING THE CROSS-CONNECTION, BACKFLOW PREVENTION, BOOSTER PUMP, AND WATER QUALITY PROTECTION FROM THE VILLAGE OF GLANDORF, OHIO

WHEREAS, it having come before Council of the Village of Glandorf, Ohio, that the necessity exists to take action to establish Cross-Connection, Backflow and Prevention, Booster Pump, and Water Quality Protection systems for the Village of Glandorf, Ohio.

BE IT ORDAINED BY THE COUNCIL OF THE VILLAGE OF GLANDORF, STATE OF OHIO, AND A MAJORITY VOTE OF THE MEMBERS THERETO CONCURRING:

- (a) All new and existing water service connections, which in the opinion of the Village endangers or can endanger the public water supply from an existing or anticipated cross-section shall be provided with an approved **backflow prevention device (BPD)**.
- (b) No person shall install or maintain a water service connection where a booster pump has been installed, unless an approved method is in place and is operational to maintain a minimum suction pressure as prescribed in the following **Ohio EPA 3745-95-07 Booster pumps** (<http://codes.ohio.gov/oac/3745-95>) requirements.
- (c) The installation of yard hydrants where water is available or accessible for drinking or culinary purposes and having drip openings below ground surface is prohibited unless such hydrants are equipped with approved devices to prevent entrance of ground water into chambers connected with the water supply.
- (d) The water user shall, at his cost on written notice by the Board of Public Affairs or his designee, install a BPD approved by the village, or his designee, of a type which meets the regulations of the Environmental Protection Agency, the Sanitary Code, and the American Water Works Association.
 - (1) If the water user fails to install an approved BPD within thirty days from receipt of written notice, or such date agreed by the parties, this Village shall:
 - A. Discontinue water service until BPD is installed, or
 - B. Install the device and charge the cost thereof to the user water sewer bill.
- (e) All BPDs shall be inspected annually on or before the anniversary date of installation of the device and shall report the results in writing to the Village.
- (f) Right of entry.
 - (1) A Village authorized representative may enter at reasonable times upon any private or public property to inspect and investigate conditions relating to the construction, maintenance, and operation of a public water system, and may take samples for analysis.
- (g) Failure to perform the annual inspection and an inspection sheet in accordance with this Ordinance or within thirty days thereof, hereof shall result in a penalty of thirty-five dollars (\$35.00) being added to the water bill of the delinquent user for each month, or portion thereof, of noncompliance.
 - (1) If after one year and one month, noncompliance continues, the water user shall be notified by certified mail of the noncompliance. If compliance with written notice to the Village is not obtained within thirty days from the notice, water service shall

Ordinance No. 1492

Passed February 5, 2019

inspection and the assessment of a fifty dollar (\$50.00) renewal of service fee, which shall be added to the user's water sewer bill.

- (h) Inspectors must provide proof of proper licensing to the Village. Such licensing may be obtained from the Ohio Department of Commerce, the Operating Training Committee of Ohio or the equivalent approved by the Municipal Director or his designee.
- (i) Any charges incurred per this Ordinance, penalty set forth in and the charges set forth in this Ordinance shall be deemed to be a "water charge" as set forth in this Ordinance and shall be a lien upon the premises being served in the same manner as set forth in such Ordinance.

That this Ordinance is effective at the earliest time allowable under the law.

Date Passed: February 5, 2019

ATTEST:


Marilyn Ellerbach
Fiscal Officer, Village of Glandorf

APPROVED:


Gene Wanke
Mayor, Village of Glandorf